



NIAGARA MOHAWK POWER CORPORATION / 300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202 / TELEPHONE (315) 474-1511

SAMUEL F. MANNO
VICE PRESIDENT
NUCLEAR CONSTRUCTION

March 7, 1983

Mr. R. W. Starostecki, Director
U.S. Nuclear Regulatory Commission
Region I
Division of Project and Resident Programs
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is a 30-day interim report in accordance with 10CFR50.55(e) for the problem concerning the Power Generation Control Complex floor module welds. This condition was reported via telecon to W. Baunack of your staff on February 7, 1983.

Very truly yours,

S. F. Manno
Vice President
Nuclear Construction

xc: Director of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. R. D. Schulz, Resident Inspector

8303210578 830307
PDR ADOCK 05000410
S PDR

IE27

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT - UNIT 2
DOCKET NO. 50-410

Interim Report for a Problem
Concerning Power Generation Control Complex
Floor Module Welds

Description of the Problem

The problem concerns the Power Generation Control Complex floor modules supplied by General Electric. General Electric's typical floor section drawings specify 0.25-in. fillet welds at beams identified as 8 in. x 18.4 lb. Niagara Mohawk Power Corporation Quality Assurance has identified a number of these welds to be less than 0.25 in. in floor modules. These modules have been delivered to the site.

This matter is still under investigation, and a final report will be submitted by May 15, 1983.