

LICENSEE EVENT REPORT

CONTROL BLOCK:

1	2	3	4	5	6
---	---	---	---	---	---

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1
---	---

 N J S G S 1 (2) 0 0 - 0 0 0 0 0 - 0 0 (3) 4 1 1 1 1 (4) (5)
7 8 9 14 15 25 26 30 57 CAT 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T

0	1
---	---

 REPORT SOURCE L (6) 0 5 0 0 0 2 7 2 (7) 0 2 1 5 8 3 (8) 0 3 0 7 8 3 (9)
7 8 60 61 68 69 74 75 80
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

(0 2) On February 15, 1983, during routine operation, the Control Room Operator discovered
(0 3) that both Nos. 11 and 12 Containment Sump Pumps were running continuously. To prevent
(0 4) damage they were de-energized and tagged out. This rendered the Containment Sump
(0 5) Monitoring System inoperable, and Action Statement 3.4.6.1 was entered. Redundant
(0 6) Reactor Coolant System leakage detection systems were operable. Due to the loss of
(0 7) redundancy, the event constituted operation in a degraded mode in accordance with
(0 8) Technical Specification 6.9.1.9b. (83-014, 81-117, 81-095, 81-056, 81-009)

0	9
---	---

 SYSTEM CODE I E (11) CAUSE CODE E (12) CAUSE SUBCODE B (13) COMPONENT CODE I N S T R U (14) COMP. SUBCODE E (15) VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20
LER RO REPORT NUMBER (17) 8 3 (21) SEQUENTIAL REPORT NO. 0 1 7 (26) OCCURRENCE CODE 0 3 (29) REPORT TYPE L (30) REVISION NO. 0 (32)
ACTION TAKEN C (18) Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0 0 0 0 (22) ATTACHMENT SUBMITTED Y (23) NPD-4 FORM SUB. Y (24) PRIME COMP. SUPPLIER A (25) COMPONENT MANUFACTURER M 0 4 0 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

(1 0) Investigation revealed that Level Detector LD-7749 was malfunctioning, apparently due
(1 1) to binding in the magnetic sleeve assembly, thereby preventing the automatic de-
(1 2) energization of No. 11 Containment Sump Pump. The device was replaced, the sump pumps
(1 3) were satisfactorily tested, and the action statement was terminated.

1	5
---	---

 FACILITY STATUS C (28) % POWER 0 0 3 (29) OTHER STATUS N/A (30) METHOD OF DISCOVERY A (31) DISCOVERY DESCRIPTION Operator Observation (32)
7 8 9 10 12 13 44 45 46 80

1	6
---	---

 RELEASED OF RELEASE Z (33) Z (34) AMOUNT OF ACTIVITY N/A (35) LOCATION OF RELEASE N/A (36)
7 8 9 10 11 44 45 80

1	7
---	---

 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) TYPE Z (38) DESCRIPTION N/A (39)
7 8 9 11 12 13 80

1	8
---	---

 PERSONNEL INJURIES NUMBER 0 0 0 (40) DESCRIPTION N/A (41)
7 8 9 11 12 80

1	9
---	---

 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION N/A (43)
7 8 9 10 80

2	0
---	---

 PUBLICITY ISSUED N (44) DESCRIPTION N/A (45)
7 8 9 10 808303210633 830311
PDR ADQCK 05000272
S PDR

NRC USE ONLY

NAME OF PREPARER R. Frahm

PHONE 609/935-6000 Ext. 3078