



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 4, 1983

US MAR 9 AIO: 43

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Mr. J. P. O'Reilly  
Regional Administrator  
Office of Inspection & Enforcement  
Region II  
101 Marietta Street, N.W.  
Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Units 1 and 2  
License No. NPF-13  
Docket Nos. 50-416/417  
File: 0260/15525/15526  
I.E. Report 416/82-65 of September 29,  
1982  
AECM-83/0152

Ref: 1) MAEC-82/225, 9/29/82  
2) AECM-82/524, 10/29/82

This letter supplements Ref. 2 concerning MP&L's response to NRC Violation 416/82-65-02. Administrative Procedure 01-S-07-1, "Control of Work on Plant Equipment and Facilities," has been revised to eliminate the use of manpower support work orders. This revision will be issued by March 15, 1983 and will read as follows:

- A) On Green Tagged Systems, MWO's requesting SRI or TIPE Support will be honored; however, MWO's requesting "Manpower Support" will not be honored.
- B) On Green and White Tagged Systems, SRI, TIPE and Manpower Support MWO's will not be honored.

Yours truly,

JDB/LFD/CKM/JPM:rg

cc: See next page

8303210703 830311  
PDR ADOCK 05000416  
Q PDR

Member Middle South Utilities System

## MISSISSIPPI POWER &amp; LIGHT COMPANY

cc: Mr. N. L. Stampley  
Mr. R. B. McGehee  
Mr. T. B. Conner

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. G. B. Taylor  
South Miss. Electric Power Association  
P. O. Box 1589  
Hattiesburg, MS 39401