

USNRC REGION II
ATLANTA, GEORGIA

USNRC REGION II
ATLANTA, GEORGIA
CP&L

PRP
Hebe
Docket File

83 JUN 21 A10:08

83 JUN 14 A12:10
Brunswick Steam Electric Plant

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

June 9, 1983

FILE: B09-13510C
SERIAL: BSEP/83-1769


Mr. James P. O'Reilly, Administrator
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-324
LICENSE NO. DPR-62
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

During Unit No. 2 power operation on May 12 and 19, 1983, respective LCOs were initiated for three fire doors in the Diesel Generator Building. The doors-- Numbers 106, 109, and 201--were each declared inoperable because of encountered high differential air pressure across each subject door which prevents automatic self-closure. Plant Engineering has been requested to evaluate the involved differential air pressure problem. Until the return of the three doors to operability and cancellation of the involved LCOs, appropriate stationed fire watches will remain in effect.

Very truly yours,


R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/sgb/LETJ03

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8306270119 830609
PDR ADOCK 05000324
S PDR

OFFICIAL COPY
IE 22
1/0