



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

June 17, 1983

JAMES P. MCGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-045/0 - Fire
Doors OC501 and OC503
Blocked Open to Allow
Performance of a Planned
Maintenance Activity
AECM-83/0345

On May 15, 1983, fire doors OC501 and OC503 on the east side of the Control Room were blocked open to allow the routing of hoses into the Control Room for the sealing of fire rated penetrations. A fire watch was established at the start of the planned maintenance activity and will be maintained for the duration in accordance with Technical Specification 3.7.7.

The doors were not closed by the seven day time limit of the action statement, therefore, this is being submitted as a Special Report pursuant to Technical Specification 6.9.2. The condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. The planned maintenance activity is expected to be completed by July 25, 1983.

Yours truly,

L J Doh
for J.P. McGaughy

JPM:sap

cc: (See Next Page)

OFFICIAL COPY

8306270165 830617
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

83 JUN 21 9:42
USNRC REGION II
ATLANTA, GEORGIA

TE 27
1/0

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0345

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555