



Carolina Power & Light Company

Brunswick Steam Electric Plant

P. O. Box 10429

Southport, NC 28461-0429

June 14, 1983

83 JUN 17 AIO: 47

USNRC REGION II
ATLANTA, GEORGIA

FILE: B09-13510C

SERIAL: BSEP/83-1875

Mr. James P. O'Reilly, Administrator
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street NW
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2

DOCKET NO. 50-324

LICENSE NO. DPR-62

SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

During Unit No. 2 power operation on May 13, 1983, an LCO was initiated for a fire door in the Diesel Generator Building. The door, number 202, was declared inoperable because of encountered high differential air pressure across the door which prevents automatic self-closure. Plant Engineering has been requested to evaluate the involved differential air pressure problem. Until the return of the subject door to operability and cancellation of the involved LCO, appropriate stationed fire watches will remain in effect.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/shb/LETSB1

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8306270245 830614
PDR ADDCK 05000324
S PDR

OFFICIAL COPY

IE 22
1/0