

Attachment A

Harrison
Bardner
Landsma



**Consumers
Power
Company**

J A Mooney
Executive Manager
Midland Project Office

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0774

June 10, 1983

Mr J J Harrison
Midland Project Section
U S Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

MIDLAND ENERGY CENTER GWO 7020
REMEDIAL SOILS WORK AUTHORIZATION
File: 0485.16 UFI: 42*05*22*04 Serial: CSC-6738
12*32

PRINCIPAL STAFF			
RA		ENF	
D/RA		SCS	
A/RA		PAO	
DEP		SLO	
QA		RC	
CE			
ME			
OL		FILE	

orig + 3 letter

letter only

attachment is sent
to SCS

As per discussions with the NRC during their May 11 and 12 site visit, attached is a report on the evaluation of the continuous sampling borings in the Service Water Pump Structure (SWPS) area. This evaluation is based on the first six borings. The report summarizes our findings included are boring logs, piezometer installation details, etc.

Based on this evaluation CPCo has determined to install the SWPS dewatering wells to elevation 570 feet. It should be noted that the NRR had suggested this elevation at the June 25, 1982 meeting, in Bethesda MD, in lieu of the investigation of the initial borings.

Based on our review, we concluded that we are ready to start work:

- 207050605 - Install Remaining Ejector Wells
- 207050600 - Install Piezometers

According to the NRC/CPCo Work Authorization Procedure, we request authorization for the above activities.

JAMooney

JAM/DWP/klm

Attachments (3) copies

8306270349 830623
PDR ADDCK 05000329
A PDR

JUN 20 1983

Attachment A

Harrison
Gardner
Anderson



**Consumers
Power
Company**

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0774

J A Mooney
Executive Manager
Midland Project Office

June 13, 1983

Mr. J. J. Harrison
Midland Project Section
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

MIDLAND ENERGY CENTER GWO 7020
REMEDIAL SOILS WORK AUTHORIZATION
File: 0485.1b UFI: 42*05*22*04 Serial: CSC-6746
12*32

We have completed our review of the documents for the activities listed below.
Based on our review, we concluded that we are ready to start the work:

207050635 - Install Dewatering Discharge System (including
headers, tank, pumps and electrical)

According to the NRC/CPCo Work Authorization Procedure, we request authori-
zation for the above activities.

JAMooney

JAM/DWP/dmh

PRINCIPAL STAFF			
RA		ENF	
D/RA		SCS	+3
A/RA		PAO	
DRPP		SLO	
DE A		RC	
DMSP			
DE			
EL			
OL		FILE	100

Dupe ~~8306230250~~
POR 1p.

JUN 20 1983