



western union

Telegram

1-011693C073 03/14/83
ICS IPHVID MVN
01791 03-14 0212P CST MVIB
ICS IPHVID NO HIT
1-009476C073 03/14/83
TLX CONSPower JKN

MAR 14 PM 2:23

50-255

148 CONSUMERS POWER JACKSON MI 13:57 EST 03-14
PMS
U.S. NUCLEAR REGULATORY COMMISSION
PALISADES PLANT SECT. CHIEF
799 ROOSEVELT AVE
GLEN ELLYN IL 60137

MSG # CBW388

TO: U S NUCLEAR REGULATORY COMMISSION
ATTN: PALISADES PLANT SECTION CHIEF
799 ROOSEVELT AVENUE
GLEN ELLYN, ILLINOIS

FROM: R H KRICH, PALISADES

CC: R B DEWITT, P-26-117B, JACKSON

W.U. 1201-SF (95-88)



western union

Telegram

D J VANDEWALLE, P-24-614B, JACKSON

THIS CONFIRMS PROMPT NOTIFICATION OF AN OCCURRENCE REPORTABLE PER
T.S. 6.9.2.A(2). ON MARCH 12, 1983, WITH SAFETY INJECTION TANK T-82D
INOPERABLE DUE TO LOW BORON CONCENTRATION, AN ADDITIONAL SAFETY
INJECTION
TANK, T-82B, BECAME INOPERABLE DUE TO LOW LEVEL. THIS CONDITION OF
TWO
INOPERABLE SAFETY INJECTION TANKS AT THE SAME TIME LASTED
APPROXIMATELY
30 SECONDS. PREPARATIONS FOR POWER REDUCTION WERE BEGUN UNTIL T-82B
WAS
RESTORED TO OPERABILITY PER T.S. 3.3.2. INITIAL REPORT WAS MADE VIA
NRC
HOT LINE ON MARCH 12, 1983.

8303240014 830314
PDR ADOCK 05000255
S PDR

TIME: 13:53 03/14/83 EST
CONNECT TIME: 58 SECONDS

1457 EST

W.U. 1201-SF (95-88)

MAR 18 1983



western union

Telegram

1517 EST

W.U. 1201-SF (95-88)