

PALISADES PLANT

Docket 50-255

NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I P A L 1 2 010-1000000-100 3 4111111 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T 01 01 6 0 5 0 0 0 2 5 5 7 0 6 0 3 8 3 8 0 6 1 7 8 3 9

REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 At 2258 on June 3, 1983, with T-82C ("C" Safety Injection Tank) inoperable

03 due to a routine evolution, a second SIT, T-82D, became inoperable due to

04 low level. The condition of two inoperable SITs at the same time lasted

05 approximately 4 minutes, at which time the level in T-82D was restored.

06 Condition reportable per T.S. 3.3.2.a and 6.9.2.a(2).

07

08

09

SYSTEM CODE S F 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE A C C U M U 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16

LER/RO REPORT NUMBER 17 EVENT YEAR 8 3 SEQUENTIAL REPORT NO. 0 3 8 OCCURRENCE CODE 0 1 REPORT TYPE T REVISION NO. 0

ACTION TAKEN X 18 FUTURE ACTION X 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER N 1 5 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 Cause attributed to leakage past the fill and drain valve on the "D" SIT

11 occurring while draining T-82C for sampling or for increasing boron concen-

12 tration. Fill and drain valves will be inspected with necessary repairs

13 being made during the next refueling outage. No threat to public health

14 or safety resulted.

15 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Alarm annunciation 32

ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

PUBLICITY ISSUED DESCRIPTION N 44 NRC USE ONLY

20 N 44 NA

8306270432 830617
PDR ADDCK 05000255
S PDR

TE22



Consumers
Power
Company

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

June 17, 1983

James G Keppler, Administrator
Region III
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DOCKET 50-255 - LICENSE DPR-20 -
PALISADES PLANT - LICENSEE EVENT REPORT 83-38 - (TWO SAFETY INJECTION TANKS
INOPERABLE)

On the reverse please find Licensee Event Report LER-38 (Two Safety Injection
Tanks Inoperable) which is reportable to the NRC per Technical Specification
6.9.2.a(2)

Brian D Johnson
Staff Licensing Engineer

CC Director, Office of Nuclear Reactor Regulation
Director, Office of Inspection and Enforcement
NRC Resident Inspector - Palisades

JUN 20 1983

11/ 1E22