



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39202

March 16, 1983

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-002/0 -
Smoke Detectors Covered to
Perform Planned Maintenance
Activity
AECM-83/0174

On February 1, 1983, smoke detectors on elevation 119 feet of the Auxiliary Building were covered in order to perform a planned maintenance activity. An hourly fire watch was established in accordance with Technical Specification 3.3.7.9. The work is currently in progress; therefore, this is submitted as an interim report. An update report will be submitted by May 15, 1983.

The current condition has no effect on the health and safety of the public and does not constitute a threat to plant safety. This is a Special Report filed pursuant to Technical Specification 6.9.2.

Yours truly,

JPM:sap
Attachment

cc: (See Next Page)

FOR J P. McGaughy JR.

OFFICIAL COPY

IE 22

8303240393 830316
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0174

Page 2

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555