

CONTROL BLOCK: ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	T	N	S	N	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	37	CAT		38

CON'T

REPORT SOURCE 01 L 6 0 5 0 0 0 3 2 7 7 0 2 1 9 8 3 8 0 3 1 8 8 3 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

SECRET NOFORN

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Unit 1 was in mode 1 at 100% with the RCS temperature and pressure at 579 degrees F

03 and 2235 psig. The ice condenser lower inlet door zone D limit switches indicated

0 4 | an open door. This required entry into LCO 3.6.5.4. There was no effect upon

05 | public health and safety. Previous occurrences - none.

06

07

0	8	
---	---	--

7 8 9 10 11 12 13 14 15 16

(17) LER/RO REPORT NUMBER [8 | 3] [—] [0 | 2 | 9] [/] [0 | 3] [1] [—] [0]
 EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
 21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER				
E	18	Z	19	Z	20	Z	21	0	0	0	0	N	22	N	23	N	24	L	25	M	3	0
33		34		35		36		37				40		41		42		43		44		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (21)

10 Investigation revealed that the Micro Switch limit switch Model No. LSH1A for the i

condenser bays 9 and 11 were out of adjustment. The limit switches were adjusted

1 2 and the ice condenser door monitoring system was returned to service. This is

13 | considered an isolated case and no further action is planned.

1 4

1 5 E 28 1 0 0 29 NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION 32 Operator observation

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES										44	45
NUMBER				TYPE	DESCRIPTION						
1	2	0	0	0	(17)	Z	(38)	NA			

		PERSONNEL INJURIES		
1	2	NUMBER	DESCRIPTION	(4)
0	0	0	0	N/A

10 11 12
9 LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION

14 2 (42) NA
B 3 10
PUBLICITY
ISSUED - DESCRIPTION (45) 8303240412 830318
PDR ADPOCK 050000007 NRC USE ONLY

2 0 N 44 NA S PDR PDR

Name of Preparer: W. C. Ludwig /M. R. Harding

Phone: (615) 870-6422