



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 15, 1983

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Penetration
AE154C Opened to Pull
Cables Through It
LER 82-172/99 X-1
AECM-83/0172

This letter submits an update to a previous report submitted on January 13, 1983. The event for which the report was submitted occurred on December 10, 1982, when penetration AE154C in the Auxiliary Building was opened in order to pull cables through it. A Special Report was submitted pursuant to Technical Specification 3.7.7.a.

A work order has been initiated to reseal the penetration assembly. Attached is LER 82-172/99 X-1, which is an interim report.

Yours truly,

[Signature]
FOR J.P. McGaughy JR.

JPM:sap
Attachment

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

IE 22