



Docket No. 50-346

License No. NPF-3

Serial No. 922

March 21, 1983

RICHARD P. CROUSE
Vice President
Nuclear
(419) 259-5221

Mr. D. G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

This is in response to your Generic Letter 83-10 (Log No. 1222) relating to the Resolution of TMI Action Item 11, K.3.5 F "Automatic Trip of Reactor Coolant Pumps", for Toledo Edison Davis-Besse Nuclear Power Station Unit 1. In compliance with your letter we would like to inform you that our intent is to submit plans and schedule for resolution of the RCP trip issue by July 1, 1983. This delay is requested so that we have sufficient time to evaluate our previous analysis that have been performed over the past years relating to the RCP trip criteria and to evaluate our present position relative to SECY 82-475 and Generic Letter 83-10.

Our current operating procedures provide guidance to the operator relative to RCP trip based on the criteria of a low RC pressure SFAS signal. These procedures will remain in effect until Emergency Operating Procedures based on the Abnormal Transient Operating Guidelines (ATOG) are instituted.

It is our intention to reference a generic submittal, as members of B&W Owners Group, which provides the technical justification for resolution of RC pump trip issue during accident and transients.

Very truly yours,

RPC:KKS

cj d/14

cc: DB-1 NRC Resident Inspector

APC/