



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 16, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-001/0 -
Smoke Detectors in the LPCS
Pump Room Covered to
Perform Planned Maintenance
AECM-83/0173

On February 2, 1983, the smoke detectors in the LPCS pump room were covered in order to perform a planned maintenance activity. An hourly fire watch was established in accordance with Technical Specification 3.3.7.9. The work is still in progress, therefore, this is submitted as a interim report. An update report will be submitted by May 15, 1983.

This condition has no effect on the health and safety of the public and does not constitute a threat to plant safety. This is a Special Report submitted pursuant to Technical Specification 6.9.2.

Yours truly,

For J.P. McGehee JR.

JPM:sap
Attachment

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Member Middle South Utilities System

8303240507 830316
PDR ADOCK 05000416
S PDR

83 MAR 22 AID: 2
NRC REGION
II
ATLANTA, GEORGIA

OFFICIAL COPY
IE 22