



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 18, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-006/0 Fire
Penetrations Opened
AECM-83/0188

On February 10, 1983, fire penetrations AE-382C and AE-384C were opened to allow performance of a planned maintenance work order. Voluntary entry into Technical Specification 3.7.7 action (a) was initiated and an hourly fire watch was established.

Presently, the maintenance work order has not been completed and the Limiting Condition for Operation is continuing. This condition does not affect the health and safety of the public and does not constitute a threat to plant safety. This is an interim Special Report submitted pursuant to Technical Specification 6.9.2. An update will be submitted by May 14, 1983.

Yours truly,

[Signature]
FOR J. P. McLaughly JR

JPM:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

10 22

8303240520 830318
PDR ADOCK 05000416
S PDR

in Middle South Utilities System