



Commonwealth Edison

Quad Cities Nuclear Power Station
22710 206 Avenue North
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-83-107

March 18, 1983

J. Keppler, Regional Administrator
Office of Inspection and Enforcement
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Reference: Quad-Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One
Appendix A, Sections 4.7.A.2.i. (Amendment 76) and
3.7.A.2.d (Amendment 77 and 78)


Enclosed please find Reportable Occurrence Report Number RO 82-26/03L-2
for Quad-Cities Nuclear Power Station.

This report is submitted to you in accordance with the requirements of
Technical Specification 6.6.B.2.b; conditions leading to operation in
a degraded mode permitted by a limiting condition of operation.

Revision 1 of Reportable Occurrence Report, RO 82-26/03L-1, provided a
summary of all Local Leak Rate Test failures and corrective actions. A
special Technical Specification change to DPR-29 permitted unit startup
with the Main Steam Line Drain Valve, M0-1-220-1, omitted from the total
Containment leakage. In compliance with the special Technical Specifica-
tion change, this valve has now been restored to an operability status.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION


N. J. Kalivianakis
Station Superintendent

NJK:DGC/bb

Enclosure

cc B. Rybak
N. Chrissotimos
INPO Records Center

8303240541 830318
PDR ADOCK 05000254
S PDR

TE22
MAR 21 1983