

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	M	S	G	G	S	1	2	0	0	-	0	0	0	0	0	0	3	4	1	1	1	1	4		5
7	8	9				14	15										25	26					30	57	CAT 58

CON'T

01	L	6	0	5	0	0	0	4	1	6	7	0	5	1	7	8	3	8	0	4	1	6	8	3	9
7	8																								

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On May 17, 1983, while in Cold Shutdown, it was determined that the Plant AC and DC Electrical Power Distribution Weekly Lineup had exceeded its late date of May 16. An LCO was entered under T.S.3.5.2, as required by the action statements of 3.8.3.2. The surveillance, as required by T.S.4.8.1.2 and T.S.4.8.3.2.1, was completed and the LCO was lifted within 2 hours. The event had no affect on the health and safety of the public and did not constitute a threat to plant safety.

09	E	D	A	X	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z
7	8																								

17	8	3	0	6	6	0	3	L	0
21	22	23	24	25	26	27	28	29	30

18	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The event was caused by improper scheduling. The surveillance was due on 5/15/83, (the end of the scheduled week). It was included in the scheduling package for the week of May 16-22. The date the task card is generated by the computer has been revised (1 week earlier) so the surveillance is included in the proper week. This is a final report.

15	8	3	0	0	0	NA	A	Surveillance Review	NA
7	8								

16	Z	Z	NA	NA
7	8			

17	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
7	8																								

18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
7	8																								

19	Z	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7	8																								

NAME OF PREPARER Ron Byrd

PHONE

SUPPLEMENTARY INFORMATION TO
LER 83-066/03 L-0

Mississippi Power & Light Company
Grand Gulf Nuclear Station - Unit 1
Docket No. 50-416

Technical Specification Involved: 3.8.3.2 and 3.5.2
Reported Under Technical Specification: 6.9.1.13.b

Event Narrative:

On May 17, 1983, it was determined that the plant AC and DC Electrical Power Distribution Weekly Lineup required by Technical Specifications 4.8.1.2 and 4.8.3.2.1 had exceeded its late date of May 16. In accordance with the action requirements of Technical Specification 3.8.3.2 and Technical Specification 3.5.2, no core alterations, handling of irradiated fuel or operations with a potential for draining the vessel were performed. The surveillance was performed satisfactorily one (1) hour and thirteen (13) minutes after discovery of the event.

The event was caused by improper scheduling. The surveillance was due to be performed on May 15 and should have been included in the scheduling package for the week of May 9-15. Due to the date the computer generates the task card (approximately May 11), the surveillance was erroneously included in the upcoming week of May 16-22. When Operations received the package on May 16, the surveillance was already overdue. The date the task card is generated has been changed so that the card is received by the schedulers prior to the week the surveillance is due. This is submitted as a final report.



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

June 16, 1983

JAMES P. MCGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Plant AC and DC Electrical
Power Distribution Weekly
Surveillance Exceeded Its
Late Date
LER 83-066/03 L-0
AECM-83/0344

On May 17, 1983, while in Cold Shutdown, it was determined that the Plant AC and DC Electrical Power Distribution Weekly Surveillance was not performed by its late date of May 16, 1983. An LCO was entered under Technical Specification 3.5.2, as required by the action statements of Technical Specification 3.8.3.2. The surveillance, as required by Technical Specifications 4.8.3.2.1 and 4.8.1.2, was completed within two hours. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-066/03 L-0 with Supplementary Information.

Yours truly,

J. P. McGaughy
for J. P. McGaughy

JPM:sap
Attachment

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555
Member Middle South Utilities System

OFFICIAL COPY
IE 22
11

USNRC REGION II
ATLANTA, GEORGIA

83 JUN 22 9:36