



Duquesne Light

Nuclear Division
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 393-6000

March 21, 1983

• Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Generic Letter 83-13 Response


Gentlemen:

This letter is in response to your concerns addressed in Generic Letter 83-13 dated March 2, 1983 (Clarification of Surveillance Requirements for HEPA Filters and Charcoal Adsorber Units in Standard Technical Specifications on ESF Cleanup Systems).

We have reviewed our Technical Specification Surveillance Requirements for HEPA filters and charcoal adsorber units and have identified the specifications requiring revision to reflect the required relationship between the guidance provided in Regulatory Guide 1.52, Revision 2, and ANSI N510-1975. In order to clarify this relationship, we will modify the wording in the Surveillance Requirements for testing the HEPA filters and charcoal adsorbers applicable to Section 3/4.7.7, Control Room Emergency Habitability Systems and Section 3/4.7.8, Supplementary Leak Collection and Release System.

When the OSC and ORC reviews are complete, we will submit the revisions necessary to incorporate the required clarification.

Very truly yours,


J. J. Carey / RFB
Vice President, Nuclear

cc: Mr. W. M. Troskoski, Resident Inspector
U. S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, PA 15077

U. S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, DC 20555

A001

8303290008 830321
PDR ADOCK 05000334
P PDR