



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

March 18, 1983
5211-83-078


Mr. R. C. Haynes
Region I, Regional Administrator
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
IE Bulletin 83-01


This letter is in response to your letter of February 25, 1983, forwarding IE Bulletin 83-01 concerning failure of reactor trip breakers. This information is being resubmitted with required Oath of Affirmation which was omitted from our March 7, 1983 response.

Sincerely,


H. D. Hukill
Director, TMI-1

HDH:RAS:vjf
Enclosure
cc: R. Conte

Sworn and Subscribed to
Before me this 18th day of
March, 1983.


Notary Public
DARLA JEAN BERRY, NOTARY PUBLIC
MIDDLETOWN BORO, DAUPHIN COUNTY
MY COMMISSION EXPIRES JUNE 17, 1985
Member, Pennsylvania Association of Notaries

ration is a subsidiary of the General Public Utilities Corporation

8303290242 830318
PDR ADOCK 05000289
Q PDR

1211

ENCLOSURE

The TMI-1 Reactor Trip Breakers are General Electric AK-2 circuit breakers. The requirements of Bulletin 83-01 do not apply since Westinghouse DB breakers are not used as Reactor Trip Breakers.

Note: Westinghouse DB breakers are used on Class IE equipment at TMI-1; however, they do not have undervoltage devices. This concern, therefore, does not affect those breakers.

The Reactor Trip Breakers at TMI-1 are tripped by an undervoltage device for which a similar concern was identified by Bulletin 79-09. The maintenance and testing described in our response are maintained current when the unit is operating.

Additional information and discussion of Scram breaker failures will be provided at the March 8, 1983, meeting with the NRC and B&W Regulatory Response Group. Specific information regarding use of Westinghouse DB-50 breakers at TMI-1 has been provided to the TMI-1 Senior Resident Inspector.