

ENCLOSURE 1

PROPOSED TECHNICAL SPECIFICATION REVISIONS

TVA BFNP TS 176 SUPPLEMENT 7

BROWNS FERRY NUCLEAR PLANT

UNITS 1, 2, AND 3

6.0 ADMINISTRATIVE CONTROLS**(b). Annual Operating Report**

A tabulation on an annual basis of the number of station, utility and other personnel (including contractors) receiving exposures greater than 100 mrem/yr and their associated man rem exposure according to work and job functions,* e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (describe maintenance), waste processing, and refueling. The dose assignment to various duty functions may be estimates based on pocket dosimeter, TLD, or film badge measurements. Small exposures totalling less than 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources shall be assigned to specific major work functions. Any mainstream safety/relief valve that opens in response to reaching its setpoint or due to operator action to control reactor pressure shall be reported.

- c. Monthly Operating Report. Routine reports of operating statistics and shutdown experience shall be submitted on a monthly basis to the Office of Inspection and Enforcement, U.S. Nuclear Regulatory Commission, Washington, D.C., 20555, with a copy to the appropriate Regional Office, to be submitted no later than the tenth of each month following the calendar month covered by the report. A narrative summary of operating experience shall be submitted in the above schedule.

2. Reportable Occurrences

Reportable occurrences, including corrective actions and measures to prevent reoccurrence, shall be reported to the NRC. Supplemental reports may be required to fully describe final resolution of occurrence. In case of corrected or supplemental reports, a licensee event report shall be completed and reference shall be made to the original report date.

6.0 ADMINISTRATIVE CONTROLS

(b). Annual Operating Report

A tabulation on an annual basis of the number of station, utility and other personnel (including contractors) receiving exposures greater than 100 mrem/yr and their associated man rem exposure according to work and job functions,* e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (describe maintenance), waste processing, and refueling. The dose assignment to various duty functions may be estimates based on pocket dosimeter, TLD, or film badge measurements. Small exposures totalling less than 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources shall be assigned to specific major work functions. Any mainsteam safety/relief valve that opens in response to reaching its setpoint or due to operator action to control reactor pressure shall be reported.

- c. Monthly Operating Report. Routine reports of operating statistics and shutdown experience shall be submitted on a monthly basis to the Office of Inspection and Enforcement, U.S. Nuclear Regulatory Commission, Washington, D.C., 20555, with a copy to the appropriate Regional Office, to be submitted no later than the tenth of each month following the calendar month covered by the report. A narrative summary of operating experience shall be submitted in the above schedule.

2. Reportable Occurrences

Reportable occurrences, including corrective actions and measures to prevent reoccurrence, shall be reported to the NRC. Supplemental reports may be required to fully describe final resolution of occurrence. In case of corrected or supplemental reports, a licensee event report shall be completed and reference shall be made to the original report date.

6.0 ADMINISTRATIVE CONTROLS(b). Annual Operating Report

A tabulation on an annual basis of the number of station, utility and other personnel (including contractors) receiving exposures greater than 100 mrem/yr and their associated man rem exposure according to work and job functions,* e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (describe maintenance), waste processing, and refueling. The dose assignment to various duty functions may be estimates based on pocket dosimeter, TLD, or film badge measurements. Small exposures totalling less than 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources shall be assigned to specific major work functions. Any mainstream safety/relief valve that opens in response to reaching its setpoint or due to operator action to control reactor pressure shall be reported.

- c. Monthly Operating Report. Routine reports of operating statistics and shutdown experience shall be submitted on a monthly basis to the Office of Inspection and Enforcement, U.S. Nuclear Regulatory Commission, Washington, D.C., 20555, with a copy to the appropriate Regional Office, to be submitted no later than the tenth of each month following the calendar month covered by the report. A narrative summary of operating experience shall be submitted in the above schedule.

2. Reportable Occurrences

Reportable occurrences, including corrective actions and measures to prevent reoccurrence, shall be reported to the NRC. Supplemental reports may be required to fully describe final resolution of occurrence. In case of corrected or supplemental reports, a licensee event report shall be completed and reference shall be made to the original report date.

ENCLOSURE 2

BROWNS FERRY NUCLEAR PLANT

SIGNIFICANT HAZARDS CONSIDERATION

TVA BFNP TS 176 SUPPLEMENT 7

1. Does the proposed amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

No. This is an administrative change which specifies annual reporting of challenges to safety/relief valves. It has been requested by NRC in NUREG-0737, item II.K.3.3 and generic letter No. 83-02.

2. Does the proposed amendment create the probability of a new or different kind of accident from any accident previously evaluated?

No. Same as (1).

3. Does the proposed amendment involve a significant reduction in a margin of safety?

No. Same as (1).