



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

June 20, 1983

JAMES P. MCGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator


Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-046/0-Fire
Door OC103 Inoperable
AECM-83/0357

On May 15, 1983, during surveillance testing, fire door OC103 was found to be damaged and in a constant alarm state. The door latch mechanism was damaged as a result of heavy use. The door is still not repaired, therefore, this is being submitted as a Special Report pursuant to Technical Specification 6.9.2.

A maintenance work authorization has been issued to the field to repair the door and the work is expected to be completed by June 30, 1983. An hourly fire watch is being conducted and will be maintained until the door is restored to operation in accordance with Technical Specification 3.7.7. The event had no affect on the health and safety of the public and did not constitute a threat to plant safety.

Yours truly,


FOR J. P. McGaughy, JR.

JPM:sap

cc: (See Next Page)

8306300175 30620
PDR ADOCK 000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE22
11

USNRC REGION I
ATLANTA, GEORGIA
83 JUN 24 09:37

MISSISSIPPI POWER & LIGHT COMPANY

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555