

8306300189 830623
PDR ADDR 05000370
PDR
5

IE 22

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

USNRC REGION II
ATLANTA, GEORGIA

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

83 JUN 27 P 1:11

June 23, 1983

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street NW, Suite 2900
Atlanta, Georgia 30303

Re: McGuire Nuclear Station Unit 2
Docket No. 50-370

Dear Mr. O'Reilly:

Please find attached Reportable Occurrence Report RO-370/83-23. This report concerns T.S. 3.5.1.2, "Each Upper Head Injection Accumulator System shall be operable with:...c. The nitrogen bearing accumulator pressurized to between 1206 and 1264 psig". This incident was considered to be of no significance with respect to the health and safety of the public.

Very truly yours,

H.B. Tucker

Hal B. Tucker

PBN:jfw
Attachment (1)

cc: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

Mr. W. T. Orders
NRC Resident Inspector
McGuire Nuclear Station

OFFICIAL COPY

IE 22 11