

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

08 7 8 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

7 8 9

7 8 9 10 68 69 80
NAME OF PREPARED: H. B. RAY PHONE 714/492-7700

IE22

8307060214 830622
PDR ADCK 05000361
S PDR

NRC USE ONLY

PHONE 714/492-7700

June 22, 1983

cc: A.E. Chaffee (USNRC Resident Inspector, Units 2 and 3)
R.J. Pate (USNRC Resident Inspector, Units 2 and 3)
J.P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U.S. Nuclear Regulatory Commission
Office of Management Information and Program Control (MIPC)

Institute of Nuclear Power Operations (INPO)

ATTACHMENT TO LER 83-055

SOUTHERN CALIFORNIA EDISON COMPANY
SAN ONOFRE NUCLEAR GENERATING STATION

UNIT NO. 2, DOCKET NO. 50-361

SUPPLEMENTAL INFORMATION FOR EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

Samples were taken simultaneously from the sampling system and from the waste gas surge tank. High oxygen concentrations were verified to exist in the sampling system, however, the waste gas surge tank samples were found to be within limits.

SUPPLEMENTAL INFORMATION FOR CAUSE DESCRIPTION AND CORRECTIVE ACTION

To prevent air inleakage to the waste gas sampling system, the waste gas compressors are being operated manually. The waste gas compressor and recirculation control systems will be repaired or readjusted to maintain adequate compressor suction pressure and the sampling system leaks will be corrected.

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY
STATION MANAGER

June 22, 1983

RECEIVED
NRC

1983 JUN 29 AM 10:49

REGION V/185

SCE

TELEPHONE
(714) 492-7700

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator


Dear Sir:

Subject: Docket No. 50-361 and 50-362
30-Day Report
Licensee Event Report No. 83-055 (Docket No. 50-361)
San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to Section 6.9.1.13.b of Appendix A, Technical Specifications to Facility Operating License NPF-10 and NPF-15 for San Onofre Units 2 and 3, this submittal provides the required 30-day written report and a copy of the Licensee Event Report (LER) 83-055 for an occurrence involving the Waste Gas Holdup System. Since this occurrence involves a shared system between Units 2 and 3, in accordance with NUREG-0161, a single LER for Unit 2 (Docket No. 50-361) is enclosed.

If there are any questions regarding this event, please contact me.

Sincerely,



Enclosure: LER 83-055

11 IE-22
83-274