

CONTROL BLOCK:

--	--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'TEVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

PHONE 714-492-7700

ATTACHMENT TO LER 83-054
SOUTHERN CALIFORNIA EDISON COMPANY
SAN ONOFRE NUCLEAR GENERATING STATION
UNIT NO. 2, DOCKET NO. 50-361

SUPPLEMENTAL INFORMATION FOR CAUSE DESCRIPTION AND CORRECTIVE ACTION

Since sticky grippers have been a problem in the past (see also LER's 82-085, 82-086, 82-088, 82-091, 82-092 and 82-128), a Control Element Drive Mechanism (CEDM) gripper change is anticipated to be incorporated during the first refueling outage. These System 80 CEDM upper and lower gripper coils have greater current carrying capability resulting in a stronger magnetic field. This will improve latching capability and they are expected to reduce the tendency for sticking. System 80 CEDM upper and lower gripper coils have already been installed on SONGS-3.

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

RECEIVED
NRC
SCE

1983 JUN 28 AM 11:06

REGION V
TELEPHONE
(714) 492-7700

H. B. RAY

STATION MANAGER

June 23, 1983

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator


Dear Sir:

Subject: Docket No. 50-361
30-Day Report
Licensee Event Report No. 83-054
San Onofre Nuclear Generating Station, Unit 2

Pursuant to Section 6.9.1.13.b of Appendix A, Technical Specifications to Facility Operating License NPF-10 for San Onofre Unit 2, this submittal provides the required 30-day written report and a copy of the Licensee Event Report (LER) form for an occurrence involving Limiting Condition for Operation (LCO) 3.3.1 associated with the Control Element Assemblies (CEA's). Enclosed LER 83-054 addresses this event, including corrective actions and measures to prevent recurrence.

If there are any questions regarding the above, please contact me.

Sincerely,



Enclosure

IE-22
83-275

Mr. J. B. Martin

-2-

June 23, 1983

cc: A.E. Chaffee (USNRC Resident Inspector, Units 2 and 3)
R.J. Pate (USNRC Resident Inspector, Units 2 and 3)
J.P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U.S. Nuclear Regulatory Commission
Office of Management Information and Program Control (MIPC)

Institute of Nuclear Power Operations (INPO)