

REACTIVITY CONTROL SYSTEMS

POSITION INDICATION SYSTEMS - OPERATING

LIMITING CONDITION FOR OPERATION

3.1.3.2.1 The shutdown and control rod position indication systems shall be OPERABLE and capable of determining the actual and demanded rod positions as follows:

- a. Analog rod position indicators, within one hour after rod motion (allowance for thermal soak);

All Shutdown Banks: + 12 steps of the group demand counters for withdrawal ranges of 0-30 steps and 200-228 steps.

Control Bank A: + 12 steps of the group demand counters for withdrawal ranges of 0-30 steps and 200-228 steps.

Control Bank B: + 12 steps of the group demand counters for withdrawal ranges of 0-30 steps and 160-228 steps.

Control Banks C and D: + 12 steps of the group demand counters for withdrawal range of 0-228 steps.

- b. Group demand counters; + 2 steps of the pulsed output of the Slave Cyclor Circuit over the withdrawal range of 0-228 steps.

APPLICABILITY: MODES 1 and 2.

ACTION:

- a. With a maximum of one analog rod position indicator per bank inoperable either:
1. Determine the position of the non-indicating rod(s) indirectly by the movable incore detectors at least once per 8 hours and within one hour after any motion of the non-indicating rod which exceeds 24 steps in one direction since the last determination of the rod's position, or
 2. Reduce THERMAL POWER to less than 50% of RATED THERMAL POWER within 8 hours.

INSERT A

C *

- b. With a maximum of one group demand position indicator per bank inoperable either:

REACTIVITY CONTROL SYSTEMS

POSITION INDICATION SYSTEMS - OPERATING

LIMITING CONDITION FOR OPERATION

3.1.3.2.1 The shutdown and control rod position indication systems shall be OPERABLE and capable of determining the actual and demanded rod positions as follows:

- a. Analog rod position indicators, within one hour after rod motion (allowance for thermal soak);

All Shutdown Banks: + 12 steps of the group demand counters for withdrawal ranges of 0-30 steps and 200-228 steps.

Control Bank A: + 12 steps of the group demand counters for withdrawal ranges of 0-30 steps and 200-228 steps.

Control Bank B: + 12 steps of the group demand counters for withdrawal ranges of 0-30 steps and 160-228 steps.

Control Banks C and D: + 12 steps of the group demand counters for withdrawal range of 0-228 steps.

- b. Group demand counters; + 2 steps of the pulsed output of the Slave Cycler Circuit over the withdrawal range of 0-228 steps.

APPLICABILITY: MODES 1 and 2.

ACTION:

- a. With a maximum of one analog rod position indicator per bank inoperable either:

1. Determine the position of the non-indicating rod(s) indirectly by the movable incore detectors at least once per 8 hours and within one hour after any motion of the non-indicating rod which exceeds 24 steps in one direction since the last determination of the rod's position, or

INSERT A

2. Reduce THERMAL POWER to less than 50% of RATED THERMAL POWER within 8 hours.

C. X.

- With a maximum of one group demand position indicator per bank inoperable either: