



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 17, 1983

83 MAR 24 All: 14

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303


Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Low System Flow on SGTS 'B'
Subsystem
LER 83-059/03 L-0
AECM-83/0185

On February 15, 1983, during performance of a 10 hour surveillance run, low system flow was observed for the Standby Gas Treatment System 'B' Subsystem. Core alterations were being made during this time period. Technical Specification 3.6.6.3 requires that two independent subsystems be operable while performing core alterations. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-059/03 L-0.

Yours truly,


FOR J.P. McGaughy JR.

JPM:sap
Attachment

cc: Mr. J. B. Richard (w/a)
Mr. R. E. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8304010293 830317
PDR ADDCK 05000416
PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22