

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 FLSL 1 00 -0 00 00 -0 00 41 11 11 11 4 5
7 3 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CON'T
01 L 05 00 00 33 5 0 2 1 7 8 3 0 3 2 1 8 3 9
7 3 REPORT SOURCE 30 31 DOCKET NUMBER 38 39 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 DURING PERIODIC TESTING AT 99% POWER, REACTOR PROTECTION SYSTEM (RPS)

03 LOGIC MATRIX RELAY AB-1 WAS FOUND TO BE FAILED. ACTION WAS TAKEN PER

04 TECHNICAL SPECIFICATION 3.3.1.1.

05 THE RELAY WAS REPLACED WITHIN ONE HOUR. THE HEALTH AND SAFETY OF THE

05 PUBLIC WERE NOT AFFECTED. THIS IS THE SECOND OCCURRENCE (SEE LER

07 335-82-47) OF THIS TYPE.

03

09 IA E A RELAY X G Z
7 8 9 10 11 12 13 14 15 16
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE

17 83 0110 03 L 6
17 21 22 23 24 25 26 27 28 29 30 31
LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

A Z Z Z 0000 N N N C 3 4 5
23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRC-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 THE C.P. CLAIR MODEL HGZX-1011 MERCURY WETTED RELAY WAS FOUND TO BE

11 ELECTRICALLY OPEN. THE RELAY WAS REPLACED IN KIND. PERIODIC TESTING

12 OF THE RPS WILL IDENTIFY FUTURE FAILURES OF THIS TYPE SHOULD THEY

13 OCCUR.

14

15 E 09 9 NA B OPERATOR OBSERVATION
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

16 Z Z NA NA NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

17 000 Z NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

18 000 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
PERSONNEL INJURIES NUMBER DESCRIPTION

19 Z NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

20 N NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
PUBLICATION ISSUED DESCRIPTION

NAME OF PREPARER R. L. Hayes PHONE (305) 465-3550

NRC USE ONLY