

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-187

UNIT PRAIRIE ISLAND 50.4

DATE JULY 9, 1983

COMPLETED BY DALE MCGILL

TELEPHONE 812-385-1101

MONTH JUNE 1983

THE UNIT WAS BASE LOADED THIS MONTH. NO SHUTDOWNS.

UNIT SHUTDOWNS AND LER REDUCTIONS

REPORT MONTH JUNE 1983DOCKET NO. 50-282UNIT NAME Prairie Island No. 1DATE July 1, 1983COMPLETED BY Dale DugstadTELEPHONE 612-388-1121

Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting ³ Down Reactor	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
6-4-83	S	0.0	B	N/A	N/A	N/A	N/A	Condenser tube cleaning Turbine valves test
6-21-83	S	0.0	B	N/A	N/A	N/A	N/A	Reduced power to locate leaks in containment

¹ F: Forced
S: Scheduled

² Reason
A-Equipment Failure(Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³ Method:
1-Manual
2-Manual Trip
3-Automatic Trip
4-Other (Explain)

⁴ Exhibit G-In-
structions for
Preparation of
Data Entry Sheets
for Licensee Event
Report (LER) File
(NUREG-0161)

⁵ Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-328

UNIT PRAIRIE ISLAND NO. 1

DATE JULY 5, 1983

COMPLETED BY DALE JOHNSON

TELEPHONE 410-228-1101

MONTH JUNE 1983

THE UNIT WAS BASE LOADED THIS MONTH. ON JUNE 3TH THE UNIT WAS REMOVED FROM SERVICE TO REPAIR LEAKING STEAM GENERATOR PRIMARY MANWAYS. THE UNIT WAS BACK ON LINE AT 1447 ON JUNE 14TH.

DAILY UNIT LOADS - SUMMARY

DOCKET NO. 50-206

UNIT PRAIRIE ISLAND NO. 1

DATE JULY 3, 1983

COMPLETED BY DALE OLCZYK

TELEPHONE 412-388-1121

MONTH JUNE 1983

DAY AVERAGE LOAD MWE-NET

1	387
2	385
3	384
4	414
5	412
6	386
7	386
8	361
9	410
10	41
11	41
12	41
13	46
14	41
15	374
16	382
17	492
18	386
19	484
20	406
21	400
22	497
23	481
24	403
25	488
26	486
27	481
28	381
29	386
30	385

AVERAGE LOADS ABOVE 500 MWE-NET ARE DUE
TO COOLER CONDENSER CIRCULATING WATER

UNIT SHUTDOWNS AND LER REDUCTIONS

REPORT MONTH JUNE 1983

DOCKET NO. 50- 302

UNIT NAME Prairie Island No. 2DATE July 1, 1983COMPLETED BY Dale DugstadTELEPHONE 612-388-1121

Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting ³ Down Reactor	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
6-8-83	S	0.0	B	N/A	N/A	N/A	N/A	Axial offset test
6-8-83	S	135.0	B	1	N/A	N/A	N/A	Repair leaking SG manways

¹ F: Forced
S: Scheduled

² Reason
A-Equipment Failure(Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³ Method:
1-Manual
2-Manual Trip
3-Automatic Trip
4-Other (Explain)

⁴ Exhibit G-In-
structions for
Preparation of
Data Entry Sheets
for Licensee Event
Report (LER) File
(NUREG-0161)

⁵ Exhibit 1 - Same Source



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

July 8, 1983

Director, Office of Resource Management
U S Nuclear Regulatory Commission
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket No. 50-282 License No. DPR-42
50-306 DPR-60

Monthly Operating Report
June, 1983

Attached are twelve copies of the Monthly Operating Report for
June, 1983 for the Prairie Island Nuclear Generating Plant.

for *Thomas H. Parker*
David Musolf
Manager of Nuclear Support Services

DMM/ js

cc: Regional Administrator-III, NRC
NRR Project Manager, NRC
NRC Resident Inspector
MPCA
Attn: J W Ferman

Attachment

IE24
1/1

Internal Correspondence

NTP

Date July 5, 1983

From E. L. Watzl, Plant Manager

Location Prairie Island

To D. M. Musolf, Manager-Nuclear Support Services

Location General Office - 8

Subject NRC MONTHLY OPERATING REPORTS

Dear Mr. Musolf:

Attached are the originals of the Unit 1 and Unit 2 NRC Monthly
Operating Reports for June 1983.

Sincerely,

E. L. Watzl
Plant Manager
Prairie Island Nuclear Plant

By Dale J. Dugstad
Dale J. Dugstad
Associate Engineer

ELW/DJD/kt

Attachments