

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
1750 Chestnut Street Tower II

March 25, 1983

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Suite 2900  
101 Marietta Street, NW  
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET  
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE OCCURRENCE  
REPORT BFRO-50-259/83010

The enclosed report provides details concerning an inoperable standby gas  
treatment filter train because of problems with flow distribution. This  
report is submitted in accordance with Browns Ferry unit 1 Technical  
Specification 6.7.2.b(2).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
H. J. Green  
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center  
Institute of Nuclear Power Operations  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

NRC Inspector, Browns Ferry

63 MAR 28 AID: 42  
BROWN REGION  
ATLANTA, GEORGIA

OFFICIAL COPY

IE 22

8304010396 830325  
PDR ADDCK 05000259  
S PDR