



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 18, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Update Report - Invalid  
Division II Diesel  
Generator Test  
LER 82-156/03 X-1  
AECM-R3/0184

This letter submits an update to a previous report submitted on December 31, 1982. The event for which the report was submitted occurred on December 4, 1982, when an invalid failure to start the Division II Diesel Generator occurred while attempting to perform a surveillance test. The event was reported pursuant to Technical Specification 6.9.1.13.c.

After investigation of the event, it has been determined the diesel failure to start was caused by personnel error. Attached is LER 82-156/03 X-1, which is a final report.

Yours truly,

*J.P. McGaughy, Jr.*  
FOR J.P. McGaughy, Jr.

JPM:sap  
Attachment

cc: Mr. J. B. Richard (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555  
Member Middle South Utilities System

83 MAR 28 A10:42

USNRC REGION II  
ATTN: ADMINISTRATOR

8304010402 830318  
PDR ADDCK 05000416  
PDR  
S

OFFICIAL COPY

IE 22