U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK / / / / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

/0/1/ /V/A/N/A/S/2/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) / / / (5)

LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

/0/1/ REPORT SOURCE /L/ (6) /0/5/0/0/0/3/3/9/ (7) /0/3/0/4/8/3/ (8) /0/3/2/3/8/3/ (9)

DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

/0/2/ / On March 4, 1983, with Unit 2 in Mode 1, Fire Door S54-7 between the Unit 1 Emer-/

/0/3/ / gency Switchgear Room and the stairway to the Control Room was declared inoper- /

/0/4/ / able because it would not close and latch automatically. Since a fire watch was /

/0/5/ / immediately posted, the public health and safety were not affected. This event /

/0/6/ / is contrary to T.S. 3.7.15 and reportable pursuant to T.S. 6.9.1.9.b. There are /

/0/7/ / no generic implications to this event. /

/0/8/ / /

SYSTEM CODE — CAUSE CODE — CAUSE SUBCODE — COMPONENT CODE — COMP. SUBCODE — VALVE SUBCODE

/0/9/ /A/B/ (11) /E/ (12) /B/ (13) /X/X/X/X/X/X/ (14) /Z/ (15) /Z/ (16)

(17) LER/RO REPORT NUMBER — EVENT YEAR — SEQUENTIAL REPORT NO. — OCCURRENCE CODE — REPORT TYPE — REVISION NO.

/8/3/ /-/ /0/2/2/ /\/ /0/3/ /L/ /-/ /0/

ACTION TAKEN — FUTURE ACTION — EFFECT ON PLANT — SHUTDOWN METHOD — HOURS — ATTACHMENT SUBMITTED — NPRD-4 FORM SUB. — PRIME COMP. SUPPLIER — COMPONENT MANUFACTURER

/B/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /A/ (25) /C/1/7/5/ (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / The door would not close because the reclosure device and latch had worked out of/

/1/1/ / adjustment. Both the reclosure device and door latch were readjusted, the door /

/1/2/ / satisfactorily tested and restored to service. There are no further actions /

/1/3/ / required. /

/1/4/ / /

FACILITY STATUS — %POWER — OTHER STATUS (30) — METHOD OF DISCOVERY — DISCOVERY DESCRIPTION (32)

/1/5/ /E/ (28) /1/0/0/ (29) / NA / /B/ (31) / Operator Observation /

ACTIVITY RELEASED — CONTENT OF RELEASE — AMOUNT OF ACTIVITY (35) — LOCATION OF RELEASE (36)

/1/6/ /Z/ (33) /Z/ (34) / NA / / NA /

PERSONNEL EXPOSURES

NUMBER — TYPE — DESCRIPTION (39)

/1/7/ /0/0/0/ (37) /Z/ (38) / NA /

PERSONNEL INJURIES

NUMBER — DESCRIPTION (41)

/1/8/ /0/0/0/ (40) / NA /

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE — DESCRIPTION

/1/9/ /Z/ (42) / NA /

PUBLICITY

ISSUED — DESCRIPTION (45) — NRC USE ONLY

/2/0/ /N/ (44) / NA / / / / / / / / / / / / /

NAME OF PREPARER E. W. HARRELL PHONE (703) 894-5151

8304010403 830323
PDR ADOCK 05000339
S PDR