



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

March 24, 1983

FILE: B09-13510C
SERIAL: BSEP/83-942

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-324
LICENSE NO. DPR-62
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

During Unit No. 2 power operation on March 12, 1983, two fire barrier LCOs were generated to permit the performance of work in the Augmented Off-Gas Building required for the installation of a plant modification. Due to the complexity of the work involved with this modification, the seven-day specified time frame of the subject LCOs has been exceeded. Until the completion of the involved modification work and cancellation of the subject LCOs, appropriate stationed fire watches will remain in effect.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/mcg/LETCG1

Enclosure

cc: Mr. R. C. DeYoung
NRC Document Control Desk

OFFICIAL COPY

8304010442 830324
PDR ADOCK 05000324
S PDR

TE 22