



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 25, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-007/0 - Fire
Penetration CE-359G Opened
to Perform Planned
Maintenance
AECM-83/0192

On February 16, 1983, while the reactor mode switch was in REFUEL, fire penetration CE-359G was opened in order to rework the penetration (planned maintenance work order). Voluntary entry into the action statement of Technical Specification 3.7.7 was initiated.

This condition had no affect on the health and safety of the public and did not constitute a threat to plant safety. When the maintenance work was completed, the fire penetration was restored. The duration of the Limiting Condition for Operation was 21 days. This is a Special Report submitted pursuant to Technical Specification 6.9.2.

Yours truly,

JPM:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8304010474 830325
PDR ADOCK 05000416
S PDR

er Middle South Utilities System

OFFICIAL COPY

TE 22

83 MAR 28
AID: 42
USNRC REGION II
ATLANTA, GEORGIA