



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 23, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
191 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Control Room Radiation Monitor
Channel Functional Test Not
Performed
LER 83-063/01 T-0
AECM-83/0190

On March 9, 1983, it was discovered that the Control Room Radiation Monitor channel functional test required by Technical Specification 4.3.7.1 was not performed at its required frequency. The test exceeded the late date by six days. The monitor was not declared inoperable during this time period; therefore, the actions of the Limiting Condition for Operation were not met. This is reported pursuant to Technical Specification 6.9.1.12.b. Attached is LER 83-063/01 T-0.

Yours truly,

James P. McGaughy, Jr.
FOR J. P. McGaughy, Jr.

JPM:sap
Attachment

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8304010526 830323
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

IE 22