

APPROVED BY OMB  
3180-0011  
EXPIRES 4-30-82

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	S	C	V	C	S	1	2	0	0	-	0	0	0	0	-	0	0	3	4	1	0	0	0	4			5	
7	8	9	LICENSEE CODE					14	15	LICENSEE NUMBER										25	LICENSE TYPE					30	37	CAT 38	

7 8 0 1 REPORT SOURCE L 6 0 5 0 0 0 3 9 5 7 0 3 0 6 8 3 8 0 3 2 5 8 3 9  
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

0 2 | On March 6, 1983, with the Plant in Mode 1, Nuclear Sampling System Valves 9398 A,  
0 3 | B, and C failed to close during the initial performance of the accelerated test  
0 4 | program established to exercise these valves on a weekly basis. No adverse  
0 5 | consequences resulted from this event. The compliance with the Action Statements  
0 6 | (a and c) of Technical Specification 3.6.4 minimized the possibility of a loss of  
0 7 | containment integrity.  
0 8 |

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE	
0	9	S	A	E	A	V	A	L	V	E	X	F	N
7	8	9	10	11	12	13	14	15	16	17	18	19	20
(17) LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE				REPORT TYPE		REVISION NO.	
8		3		18		03				L		0	
21		22		23		24				25		26	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.	
A	C	Z	Z	000		Y		N		A		COMPONENT MANUFACTURER	
33	34	35	36	37		38		39		40		41	
18	19	20	21	22		23		24		25		26	

1 0 | The event was due to crud buildup on the valve seats. Valve 9398C also  
1 1 | experienced a limit switch failure which interfered with position indication.  
1 2 | The crud was dislodged, and the limit switch repaired. The licensee plans to  
1 3 | replace the valves when a suitable alternate is obtained and will continue an  
1 4 | accelerated test program.

FACILITY STATUS (1) 5 (2) B (3) 0 (4) 5 (5) 0 (6) 29 (7) N/A (8) 30

METHOD OF DISCOVERY (9) 0 (10) 31 (11) Accelerated Test Program (12) 32

ACTIVITY CONTENT RELEASED OF RELEASE (13) 7 (14) 33 (15) 7 (16) 34 (17) N/A (18) 35

AMOUNT OF ACTIVITY (19) 44 (20) 45 (21) 46 (22) N/A (23) 36

LOCATION OF RELEASE (24) 37

PERSONNEL EXPOSURES NUMBER (25) 1 (26) 7 (27) 0 (28) 0 (29) 0 (30) 37 (31) Z (32) 38 (33) N/A (34) 39

PERSONNEL INJURIES NUMBER (35) 1 (36) 8 (37) 0 (38) 0 (39) 0 (40) 40 (41) N/A (42) 41

LOSS OF OR DAMAGE TO FACILITY TYPE (43) 1 (44) 9 (45) 7 (46) 42 (47) N/A (48) 43

PUBLICITY ISSUED DESCRIPTION (49) 2 (50) 0 (51) N (52) 44 (53) N/A (54) 45

NRC USE ONLY (55) 46 (56) 47 (57) 48 (58) 49 (59) 50 (60) 51 (61) 52 (62) 53 (63) 54 (64) 55 (65) 56 (66) 57 (67) 58 (68) 59 (69) 60

PHONE: (803) 345-5209