



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

March 24, 1983

FILE: B09-13510C
SERIAL: BSEP/83-941

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street NW
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
DOCKET NO. 50-325
LICENSE NO. DPR-71
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

During a Unit No. 1 refueling outage, five fire barrier LCOs with issuance dates of March 2, 3, 7, and 8 were generated to permit the performance of work in the Augmented Off-Gas and Control Buildings required for the installation of the three plant modifications. Due to the complexity of the work involved with these modifications, the seven-day specified time frame of each subject LCO has been exceeded. Until the completion of the involved modification work and cancellation of the subject LCOs, appropriate station fire watches will remain in effect.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/shb/LETJ03

Enclosure

cc: Mr. R. C. DeYoung
NRC Document Control Desk

OFFICIAL COPY

8304010593 830324
PDR ADOCK 05000325
S PDR

IE 22