

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 PASES100-000000-000341111145
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

CONT

01 REPORT SOURCE L050003870606830706839
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During surveillance testing (monthly operational check), the "B" train of the

03 Standby Gas Treatment System (SBGT) tripped shortly after starting. Limiting con-

04 dition for operation 3.6.5.3 was entered. The "A" train had just successfully

05 completed its monthly operability check. There were no consequential effects

06 to public health and safety.

07

08

09

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

09 SC11 A12 A13 ZZZZZZ14 Z15 Z16

17 LER/RO REPORT NUMBER 83

18 ACTION TAKEN H

19 FUTURE ACTION Z

20 EFFECT ON PLANT Z

21 SHUTDOWN METHOD Z

22 HOURS 0000

23 SEQUENTIAL REPORT NO. 089

24 OCCURRENCE CODE 03

25 REPORT TYPE L

26 REVISION NO. 0

27 ATTACHMENT SUBMITTED N

28 NRC-4 FORM SUB. N

29 PRIME COMP. SUPPLIER Z

30 COMPONENT MANUFACTURER 2999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The controls for the Outside Air Makeup Damper were placed in the 100% closed

11 position instead of 100% open as required by procedure. This eliminated the

12 flowpath which allows the system to start thereby resulting in the trip. This

13 event is to be reviewed with each shift.

14

15 FACILITY STATUS B 28 10029 NA 30 METHOD OF DISCOVERY B31 Operator Observation 32

16 ACTIVITY CONTENT RELEASED OF RELEASE Z33 Z34 NA 35 LOCATION OF RELEASE 36

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 00037 Z38 NA


18 PERSONNEL INJURIES NUMBER DESCRIPTION 41 00040 NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43 Z42 NA

20 PUBLICITY ISSUED DESCRIPTION 45 N44 8307180264 830706 PDR ADDCK 05000387 S PDR

NAME OF PREPARER A.P. Piemontese

NRC USE ONLY
PHONE 717-542-2181 X3246



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

July 6, 1983


Mr. J.M. Allan
Acting Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-089/03L-0
ER 100450 FILE 841-23
PLA-1739

Docket No. 50-387
License No. NPF-14

Dear Mr. Allan:

Attached please find a copy of Licensee Event Report No. 83-089/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that the "B" train of the Standby Gas Treatment System tripped during performance of monthly surveillance testing. The outside air makeup damper was placed in the wrong position and resulted in the trip. The test was subsequently performed successfully with the damper in the proper position.


H.W. Keiser
Superintendent of Plant-Susquehanna

APP/pjg

cc: G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

IER
11