



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

March 22, 1983

EQ-373

James G. Keppler
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Sir:

In accordance with LaSalle County Station Unit 1 Facility Operating License NPF-11, Appendix B, Section 3.2, we are submitting to you a copy of the NPDES non-compliances for LaSalle County Nuclear Generating Station Permit No. IL0048151.

G. J. Diederich
Superintendent
LaSalle County Station

GJD/FRL/JDW/rg

Enclosure

cc: DVR Report

MAR 28 1983

MAR 28 1983

8304040285 830322
PDR ADOCK 05000373
S PDR

IE22



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

March 7, 1983

U.S. Environmental Protection Agency
Region V, Enforcement Division
ATTN: Chief, Compliance Unit
230 South Dearborn Street
Chicago, IL 60604


Illinois Environmental Protection Agency
Division of Water Pollution Control
Compliance Management Unit
2200 Churchill Road
Springfield, IL 62706

Dear Sir:

Subject: NPDES Noncompliances for LaSalle County Nuclear
Generating Station - Permit No. IL0048151

In accordance with Standard Condition 12, we wish to submit the following notice of noncompliances, which are listed chronologically in the attached table.

If there are any questions, please contact Joe Williams of my staff at (815) 357-6761, extension 201.


G. J. Diederich
Station Superintendent

FRL-JOW
GJD/FRL/JDW/lrw

cc: Director of Water Quality, Environmental Affairs
Manager, Nuclear Stations Division

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: 001a Cooling Pond Blowdown

PARAMETER AND PERMIT LIMIT: Total suspended solids, zero above background

NONCOMPLIANCE, DATE, AND DURATION: 30 mg/l, FEB 83, 28 day average
Background 21 mg/l, FEB 83, 28 day average

CAUSE OF NONCOMPLIANCE:

The cause of this noncompliance is unknown.

CORRECTIVE ACTION:

The station plans no corrective action at this time.

DATE RECOGNIZED AS A VIOLATION:

1MAR83

DATE INVESTIGATED:

2MAR83