

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 I L D R S 2 00 - 000000 - 000 411111 4 5
7 8 9 14 15 25 26 37 CAT 38
LICENSEE CODE LICENSE NUMBER LICENSE TYPE

01 REPORT SOURCE L 05000237 022483 032583 9
7 8 9 50 51 58 59 74 75 80
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During unit refueling outage, while performing mechanical snubber visual and
03 stroke testing, snubber 43 and 52 pipe clamp bolt and nut were found to be loose
04 (T.S.4.6.I.1). Event of minimal safety significance since the attached snubber
05 was operable. No previous event of this type.
06
07
08

09 SYSTEM CODE C C 11 CAUSE CODE A 12 CAUSE SUBCODE E 13 COMPONENT CODE S U P O R T 14 COMP. SUBCODE D 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20
17 LER/RO REPORT NUMBER 83 EVENT YEAR 21 22 SEQUENTIAL REPORT NO. 016 OCCURRENCE CODE 03 REPORT TYPE L 31 REVISION NO. 0
32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
B 18 Z 19 Z 20 Z 21 0000 N 23 N 24 N 25 P 029 28
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The probable cause of this event was inadvertently not tightening the bolt and nut
11 sufficiently during installation. The pipe clamp bolt and nut were tightened.
12 Snubber inspection will continue to be performed as required by the Technical
13 Specification.
14

15 FACILITY STATUS H 28 % POWER 000 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 Visual inspection and stroke test 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
15 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
17 PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION 39 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
13 PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION 41 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
13 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION 43 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
20 PUBLICITY ISSUED N 44 DESCRIPTION 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

NAME OF PREPARER Sang Rhee

PHONE: (815)942-2920 Ext. 548

8304040474 830324
PDR ADOCK 05000237
S PDR

NRC USE ONLY