



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN

VICE PRESIDENT
NUCLEAR

March 25, 1983

Mr. James G. Keppler
Regional Administrator, Region III
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Piping Supports Supplied by
Transamerica Delaval, Inc.
[RDC 67(83)]

Dear Mr. Keppler:

This letter is an interim report pursuant to 10CFR50.55(e) concerning ASME Code Section III, Class 3, piping supports supplied to the Perry Nuclear Power Plant by Transamerica Delaval, Inc. Mr. P. R. Pelke of your office was first notified on February 23, 1983, by Mr. E. Riley of The Cleveland Electric Illuminating Company (CEI) that this problem was being evaluated.

This report contains a description of the deficiency, of the method planned for completion of the evaluation, and the date for submittal of our next report on this subject.

Description of Deficiency

Specification 562-4549-00, Section 2:05 Item 3a and Section 2:16 Item 1, require that most piping components are to be built to the ASME Code Section III, Class 3. Transamerica Delaval, contracted under specification 562-4549-00, supplied skid mounted piping supports without material certification and identification as outlined in ASME NF-2130 and NF-2150.

Completion of Evaluation

The Cleveland Electric Illuminating Company is currently obtaining design information from Transamerica Delaval to determine whether modifications will be necessary to meet the requirements of Section III of the ASME Boiler and Pressure Vessel Code. The vendor is marking the assembly drawings to indicate

MAR 28 1983

8304040533 830325
PDR ADOCK 05000440
S PDR


IE27

March 25, 1983

code breaks. CEI and Gilbert Associates, the Architect/Engineer, will review the drawings for compliance with the Code and Specification 562-4549-00, and determine whether modifications are needed. Completion of this action is expected by April 30, 1983, and we are planning to submit our next report at that time.

Please call if there are additional questions.

Sincerely,



Murray R. Edelman
Vice President
Nuclear Group

MRE:pab

cc: Mr. M. L. Gildner
NRC Site Office

Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D.C. 20555

Records Center, SEE-IN
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339