

Unit 3

# LICENSEE EVENT REPORT

Report No. 3-83-007/01T-0

CONTROL BLOCK:                      ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 P A P B S 3 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4                     

CON'T  
0 1 L 6 0 5 0 - 0 2 7 8 7 0 3 0 3 8 3 8 0 3 1 7 8 3                     

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

0 2 On March 3, 1983, with Unit 3 shutdown for refueling, a small quantity  
0 3 of slightly contaminated water was released from the Unit 3 reactor  
0 4 building into the storm drain system. The dilution of the small amount  
0 5 of radioactive water discharged by additional water in the storm drain  
0 6 system resulted in no detectable release to the river. Previous similar  
0 7 occurrence 3-81-13/1T. Applicable Tech Spec is 3.8.

0 8  
0 9  
SYSTEM CODE C F ⑪ CAUSE CODE X ⑫ CAUSE SUBCODE Z ⑬ COMPONENT CODE Z Z Z Z Z Z ⑭ COMP SUBCODE Z ⑮ VALVE SUBCODE Z ⑯  
LER/RO REPORT NUMBER 8 3 ⑰ SEQUENTIAL REPORT NO. 0 0 7 ⑱ OCCURRENCE CODE 0 1 ⑲ REPORT TYPE T ⑳ REVISION NO. 0 ㉑  
ACTION TAKEN X ⑳ FUTURE ACTION X ㉒ EFFECT ON PLANT Z ㉓ SHUTDOWN METHOD Z ㉔ HOURS 0 0 0 0 ㉕ ATTACHMENT SUBMITTED Y ㉖ NPRD-4 FORM SUB. N ㉗ PRIME COMP. SUPPLIER Z ㉘ COMPONENT MANUFACTURER Z 9 9 9 ㉙

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉚

1 0 The release was caused by inadvertent initiation of the A and B RHR  
1 1 pumps. The water overflowed the open reactor cavity and fuel pool and  
1 2 drained to the storm drain system under railroad doors at elevation  
1 3 135 ft. The release path was isolated, sampling begun and the small  
1 4 water in the catch basin was pumped to radwaste for processing.

1 5 FACILITY STATUS H ㉞ % POWER 0 0 0 ㉟ OTHER STATUS N/A ㊱ METHOD OF DISCOVERY A ㊲ DISCOVERY DESCRIPTION Refuel Floor Flooding ㊳  
1 6 ACTIVITY CONTENT RELEASED OF RELEASE L ㊴ AMOUNT OF ACTIVITY .000316 Ci ㊵ LOCATION OF RELEASE Storm drain to river ㊶  
1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 ㊷ TYPE Z ㊸ DESCRIPTION N/A ㊹  
1 8 PERSONNEL INJURIES NUMBER 0 0 0 ㊺ DESCRIPTION N/A ㊻  
1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z ㊼ DESCRIPTION N/A ㊽

2 0 PUBLICITY ISSUED Y ㊾ DESCRIPTION Press Release ㊿  
NRC USE ONLY  
8304050262 830317  
PDR ADDCK 05000278  
S PDR  
(215) 841-5020