

# NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY  
THE HARTFORD ELECTRIC LIGHT COMPANY  
WESTERN MASSACHUSETTS ELECTRIC COMPANY  
HOLYOKE WATER POWER COMPANY  
NORTHEAST UTILITIES SERVICE COMPANY  
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
(203) 666-6911

March 22, 1983  
MP-4813

Mr. Ronald C. Haynes  
Regional Administrator, Region 1  
U. S. Nuclear Regulatory Commission Regional Office  
631 Park Avenue  
King of Prussia, PA. 19406

Reference: Facility Operating License No. DPR-65  
Docket No. 50-336  
Reportable Occurrence RO-50-336/81-018/3X-2

Dear Mr. Haynes:

This letter forwards Licensee Event Report 81-018/3X-2 required to be submitted within thirty days pursuant to Millstone Unit 2 Appendix A Technical Specifications, Section 6.9.1.9.b, conditions leading to operation in a degraded mode permitted by a limiting condition for operation. This Update Report is submitted to reflect completion of the long term corrective action specified in the original report. All (IN) International Nuclear Safeguards Company mechanical snubbers installed on safety related piping systems have been replaced with Pacific Scientific mechanical snubbers. An additional three copies of the report are enclosed.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

E. J. Mroczka

Station Superintendent  
Millstone Nuclear Power Station

FJM/SS:mo

Attachment: LER 81-018/3X-2

cc: Director, Office of Inspection and Enforcement, Washington, D. C. (30)  
Director, Office of Management Information and Program Control,  
Washington, D. C. (3)  
U. S. Nuclear Regulatory Commission, c/o Document Management Branch,  
Washington, D. C. 20555

8304050370 830322  
PDR ADOCK 05000336  
S PDR

IE22