



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 16, 1983

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

CORRECTED COPY

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 1900
Atlanta, Georgia 30303

Previous letter noted
attachments; attachment
notation not needed.

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-001/0 -
Smoke Detectors in the LPCS
Pump Room Covered to
Perform Planned Maintenance
AECM-83/0173

On February 2, 1983, the smoke detectors in the LPCS pump room were covered in order to perform a planned maintenance activity. An hourly fire watch was established in accordance with Technical Specification 3.3.7.9. The work is still in progress, therefore, this is submitted as a interim report. An update report will be submitted by May 15, 1983.

This condition has no effect on the health and safety of the public and does not constitute a threat to plant safety. This is a Special Report submitted pursuant to Technical Specification 6.9.2.

Yours truly,

FOR J. P. McGaughy, Jr.

JPM:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY
IE 19

8304050382 830316
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System