

## TELECOPY MESSAGE

DESIGNATED ORIGINAL

TELEPHONE MESSAGE Certified By marTO: 215-337-5324 FROM: 315-343-2110 DATE/TIME 3/16/83/12:40 p.m.  
Telephone Number Telephone Number315-475-1511, ext. 1882TO: R.C. Haynes  
Regional Administrator  
USNRC Region I  
631 Park Avenue  
King of Prussia, PA. 19406From: Niagara Mohawk Power Corporation  
Nine Mile Point Nuclear Station  
Unit #1  
P.O. Box #32  
Lycoming, New York 13093SUBJECT: PROMPT REPORTABLE OCCURRENCE  
DOCKET NO. 50-220 LICENSE NO. DPR-63  
ASSIGNED LER NO. 83-05EVENT DATE: 3/15/83 REPORT DATE: 3/16/83

## EVENT DESCRIPTION:

SEE ATTACHMENT

COMPONENTS INVOLVED: Emergency Ventilation System

## CAUSE AND REMEDIAL ACTION:

SEE ATTACHMENT

## FACILITY STATUS:

% THERMAL MW 0c) Routine Startup \_\_\_\_\_  
d) Routine Shutdown \_\_\_\_\_  
e) Steady State Oper \_\_\_\_\_  
f) Load Change \_\_\_\_\_g) Shutdown X - Major Maintenance  
h) Refueling \_\_\_\_\_  
i) Other \_\_\_\_\_  
j) Not Applicable \_\_\_\_\_

A written follow-up report will be sent within two weeks.

TELECOPY TO R.C. Haynes FROM T.J. Perkins DATE 3/16/83  
NAME  
T.E. Lempges NAME  
\_\_\_\_\_  
\_\_\_\_\_

APN-21 -19 April 1979

8304050470 830316  
PDR ADDCK 05000220  
S PDR

IF 29

ATTACHMENT

ILR 83-05

EVENT DESCRIPTION

Cleanup sludge tank vent overflowed into Reactor Building Exhaust Ventilation System causing emergency ventilation system to initiate.

CAUSE AND REMEDIAL ACTION

During cleanup system flushing to the cleanup filter sludge tank, the tank overflowed through the vent to the Reactor Building Exhaust Ventilation System. The emergency ventilation system initiated on high radiation in the Reactor Building exhaust duct and normal exhaust ventilation isolated. Decontamination of exhaust ductwork is in progress.