

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
THE HARTFORD ELECTRIC LIGHT COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

March 21, 1983
MP-4811

Mr. Ronald C. Haynes
Regional Administrator, Region 1
U. S. Nuclear Regulatory Commission Regional Office
631 Park Avenue
King of Prussia, PA. 19406

Reference: Facility Operating License No. DPR-65
Docket No. 50-336
Reportable Occurrence RO-50-336/80-12/3X-1

Dear Mr. Haynes:

This letter forwards Licensee Event Report 80-12/3X-1 required to be submitted within thirty days pursuant to Millstone Unit 2 Appendix A Technical Specifications, Section 6.9.1.9.b, conditions leading to operation in a degraded mode permitted by a limiting condition for operation. This update report is submitted to reflect completion of the long term corrective action stated in the original report. All originally installed hydraulic snubbers on the Main Steam Lines to the High Pressure Turbine were functionally tested and replaced or overhauled during the summer 1980 Refueling Outage.

An additional three copies of the report are enclosed.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in cursive script, appearing to read 'E. J. Mroczka'.

E. J. Mroczka
Station Superintendent
Millstone Nuclear Power Station

EJM/SLS:mo

Attachment: LER 80-12/3X-1

cc: Director, Office of Inspection and Enforcement, Washington, D. C. (30)
Director, Office of Management Information and Program Control,
Washington, D. C. (3)
U. S. Nuclear Regulatory Commission, c/o Document Management Branch,
Washington, D. C. 20555

8304050504 830321
PDR ADDCK 05000336
S PDR

IE22