



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 30, 1983

83 APR 4 AIO: 40

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Omission of
Smoke Detectors from
Original Plant Design
LER 82-060/01 X-1
AECM-83/0175

This letter submits an update to a previous report submitted on September 22, 1982. The event for which the report was submitted occurred on September 10, 1982, when during an inspection by the Fire Protection Coordinator, two areas in the Auxiliary Building containing safety related cable were found to have no smoke detectors.

Based on a preliminary evaluation, it has been determined that smoke detectors are not needed in Room 1A605. A design change has been requested and installation of smoke detectors in stairwell 1A12 is scheduled in the near future. An hourly fire watch was established on the event date and will be maintained until smoke detector installation is complete. Attached is LER 82-060/01 X-1, which is an interim report.

Yours truly,

J.P. McGaughy, Jr.
FOR J.P. McGaughy, Jr.

JPM:sap
Attachment

cc: (See Next Page)

8304070128 830330
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

IE 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0175

Page 2

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGhee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555