



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 30, 1983

83 APR 4 AID 43

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-012/0 - Fire
Rated Seals Broken to
Perform Planned Maintenance
Activities
AECM-83/0204

From February 22, 1983, to March 16, 1983, numerous fire rated seals were opened to perform planned maintenance activities. Voluntary entry into Action (a) of Technical Specification 3.7.7 was made. The penetrations affected are listed on the attached page.

This condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. The seals were opened to perform planned maintenance activities. An hourly fire watch is being conducted and will be maintained until work is complete. Estimated completion date for the work tasks is May 15, 1983. An update report will be submitted by May 30, 1983. This is a Special Report submitted pursuant to Technical Specification 6.9.2.

Yours truly,

FOR J.P. McGaughy JR.

JPM:sap

cc: (See Next Page)

8304070169 830330
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

Te 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0204

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

<u>Electrical Penetrations</u>	<u>Date</u>
CE-82C	2/22/83
CE-201D	3/05/83
CE-202D-A	3/05/83
AE-279C	3/07/83
AE-177D	3/07/83
AE-61E	3/07/83
AE-11F	3/07/83
AE-1G	3/07/83
CE-268D	3/07/83
CE-415B	3/07/83
AE-30B	3/08/83
AE-82C	3/08/83
AE-91D	3/08/83
CE-82E	3/09/83
AE-432B	3/09/83
TE-14B	3/09/83
AE-175B	3/11/83
CE-26G	3/12/83
CE-4C	3/12/83
CE-272D	3/12/83
CE-29G	3/11/83
CE-31C	3/11/83
CE-230DA	3/14/83
AP-124C	3/16/83
AC-85B	3/16/83
AC-86B	3/16/83
AC-84B	3/16/83
AC-83B	3/16/83
AC-46E	3/16/83
AC-71D	3/16/83
AC-90C	3/16/83
AP-125C	3/16/83
Equipment Hatch, Ele. 208	3/16/83

<u>Fire Dams Opened</u>	<u>Date</u>
L092-LA21	3/11/83
L043-LA45	3/14/83
L043-LA58	3/14/83
L090-LA1	3/14/83
L089-LA18	3/14/83
L095-LA58	3/14/83
L094-LA38	3/14/83
L050-LA26	3/14/83
L049-LA25	3/14/83
L012-LA46	3/14/83
L012-LA45	3/14/83
L012-LA58	3/14/83
L043-LA46	3/14/83

<u>Cable Tray Covers Removed</u>	<u>Date</u>
1AETWL01 - 1AETWL05	3/11/83
1AETWL15	3/11/83