

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

E. A. BORGMANN
SENIOR VICE PRESIDENT

March 29, 1983
LOZ-83-0006

Docket No. 50-358

U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Attention: Mr. J.G. Keppler
Regional Administrator

Gentlemen:

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1
10CFR50.55(e) - ITEM M-33 - USE OF HIGH STRESS
STAMP ON ASME FITTINGS
W.O. 57300, JOB E-5590, FILE NO. 956C, M-33

This letter constitutes an interim report concerning the subject condition, initially reported to the NRC as 10CFR50.55(e), Item M-33.

The QCP has completed its walkdown of fittings identified as having a high stress stamp applied. Eighteen (18) fittings have been identified with indications of having high stress stamps applied.

A Construction Work Authorization Request (CWAR) is being prepared for submittal to the NRC requesting permission to blend grind these indicated high stress stamps under the November 12, 1982 "Show Cause Order and Immediately Suspending Construction". The blend grinding should be complete approximately two months after NRC work authorization is received in this area. To assure that all fittings under Purchase Order #7070-11999 have been addressed, a complete documentation review is being accomplished by Task III of the Zimmer Quality Confirmation Program. A follow-up report will be submitted by July 15, 1983.

8304070328 830329
PDR ADOCK 05000358
S PDR

APR 4 1983


IE27

Mr. J.G. Keppler
Regional Administrator
March 29, 1983
LOZ-83-0006
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By 
E.A. BORGMANN
SENIOR VICE PRESIDENT

FHS/HRS/bcf

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
Attn: W.F. Christianson
Zimmer Project Inspector
Region III