



State of New Jersey
Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625-0415
Tel (609) 987-2032
Fax (609) 987-6354

September 5, 1994

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Amendment to Facility Operating License
Technical Specification Change Request No. 219

The subject request was submitted to the NRC by GPU Nuclear letter dated July 8, 1994. The request proposes to modify page 2.3-3 of the Oyster Creek Nuclear Generating Station (OCNGS) Technical Specifications to allow the degraded voltage setpoint to be raised from 3671 volts to 3840 volts. The setpoint tolerance range will be decreased from the old range of $\pm 1.0\%$ to a new range of $\pm 0.5\%$, -1.0% . This engineering review has found that the proposed specifications are more restrictive than the current requirements. This submittal does not change the current degraded voltage time delay setting.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering (BNE) has reviewed the request within the requirements of 10 CFR 50.91(b) and has no comments. If you have any questions, please contact David Vann at (609) 987-2053 or Rich Pinney at (609) 987-2086.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

9409150114 940905
PDR ADDCK 05000219
P PDR

New Jersey is an Equal Opportunity Employer
Recycled Paper

A001
10

c: Distribution

Distribution

J. Lipoti
N.J. DEP

D. Zannoni
N.J. DEP

D. Chawaga
NRC Region I State Liaison Officer

L. Briggs
NRC Sr. Resident Inspector

A. Dromerick
NRC Project Manager

M. Laggert
GPU Nuclear

BNE/NES Staff