

LICENSEE EVENT REPORT

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 C A S 0 S 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 31 CAT 58

CONT

01 REPORT SOURCE L 6 0 5 0 0 0 3 6 1 7 0 2 2 7 8 13 8 0 13 2 9 8 3 9
7 8 80 81 86 87 90 91 92 93 94 95 96 97 98 99

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 With Unit 2 in Mode 5 and Unit 3 in Mode 4 during routine shift surveillance, Channel B
03 ammonia analyzer was declared inoperable when it failed its Technical Surveillance per
04 Section 4.3.2.1. LCO 3.3.2 was invoked. As required by the Action Statement associated
05 with this LCO, actions were immediately initiated to restore the inoperable channel
06 within 7 days. Since the redundant channel remained operable throughout the event,
07 there was no impact on health and safety of plant personnel or the public.

08

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE
S G 11 E 12 X 13 I N S T R U 14 E 15 Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 EVENT YEAR 8 3 21 22 SEQUENTIAL REPORT NO 0 2 3 24 25 OCCURRENCE CODE 0 3 26 27 REPORT TYPE L 30 31 REVISION NO 0 32 33

ACTION TAKEN E 18 19 FUTURE ACTION Z 20 EFFECT ON PLANT Z 21 SHUTDOWN METHOD Z 22 HOURS 0 0 0 0 22 23 ATTACHMENT SUBMITTED N 24 NPD-4 FORM SUB N 25 PRIME COMP. SUPPLIER A 26 COMPONENT MANUFACTURER B 1 3 5 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 Inoperability of the channel was attributed to normal instrument drift. The channel
11 was recalibrated and returned to service in accordance with Procedure S023-3-3.25 at
12 1700 on February 28, 1983. No further action is planned.

13

14

15 FACILITY STATUS B 26 27 % POWER 0 0 0 28 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 32 DISCOVERY DESCRIPTION Surveillance testing 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

16 ACTIVITY CONTENT RELEASED Z 33 34 Z 35 AMOUNT OF ACTIVITY NA 36 LOCATION OF RELEASE NA 37 38 39 40 41 42 43 44 45 46 47

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 38 TYPE Z 39 DESCRIPTION NA 40 41 42 43 44 45 46 47

18 PERSONNEL INJURIES NUMBER 0 0 0 40 41 DESCRIPTION NA 42 43 44 45 46 47

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 43 DESCRIPTION NA 44 45 46 47

20 PUBLICITY ISSUE N 44 45 DESCRIPTION NA 46 47

21

22

23 NAME OF PREPARED H. B. Ray 714/492-7700 PHONE